

FOR INDIVIDUAL GEN-SET MODEL TYPES SEE BROADCROWN LITERATURE.



GeneratorJoe

4016 Quartz Drive
Santa Rosa, CA 95405
Phone: 707 539-9003
Fax: 707 539-5212

Email: sales@generatorjoe.NET
Web www.generatorjoe.NET

ISS	ALTERATIONS	DATE
B	EXHAUST OUTLET DETAIL AND POSITION CHANGED, BELLOWS SIZE INCREASED FROM 4" TO 5". CABLE ENTRY DETAIL ADDED, PANEL HEIGHTS CORRECTED.	05-10-07 P.R
C	PLAN VIEW ADDED.	25-04-08 P.R

A ENGINE TYPE: 6081H
ALTERNATOR: UCDI 274

USABLE FUEL CAPACITY: 380 LITRES




SHIPPING WEIGHT
(WITH OIL): 1960-2110 Kg's

B WET WEIGHT
50/50 GLYCOL & FUEL: 2355-2505 Kg's

OIL CAPACITY: 32.0 LITRES
COOLING CAPACITY: 37.0 LITRES

C GENERATOR IS TO BE PLACED ON
A FLAT FLOOR OR CONCRETE BASE

PLEASE NOTE WEIGHTS MAY VARY
DEPENDING ON ALTERNATOR COMBINATION



NOTES

TOLERANCES:
BETWEEN HOLE CENTRES & HOLE CENTRE TO EDGE (ON FLAT) ± 0.2


HOLE CENTRES TO BEND AND EDGES TO BEND ± 0.5

ACROSS EACH BEND ± 0.5

FABRICATION ± 1.0

HOLE DIAMETERS AND SLOT WIDTHS $+0.1, -0.0$

ANGULAR $\pm 0.5^\circ$



THIRD ANGLE PROJECTION
DO NOT SCALE, IF IN DOUBT ASK

DISTRIBUTION

MASTER	FABRICATOR
--------	------------

TITLE:	OPEN FRAME 5-6081H GA		
CLIENT:			
SITE:			
W.O. No.:	ENGINEER:	P.RUTTER	
TYPE:	CHECKED:		
SCALE:	1:20	DATE:	

TOTAL No. OF SHEETS:

DRAWING NO.	JGA035	ISSUE	C
--------------------	--------	--------------	---

BROADCROWN