

# UL 1008 Withstand & Closing Ratings

When used with Specific Coordinated Breakers!!

Maximum Circuit Amps at 480 VAC

*Includes ZTG 260A Upgrade (in process)*

GE Zenith Controls, Chicago, IL

17 June 2003, Compiled by Steve Mecker

Amps	ZTS		ZTSD		ZTSCT		ZBTS		ZBTSD		ZBTSCT		ZTG		ZTGD		ZTX		Amps	
40	F17	30,000	F14B	50,000	no F14		#N/A		#N/A		no F14		F17	30,000	F14B	50,000	F17	30,000	40	
80		30,000		50,000	no F14		#N/A		#N/A		no F14			30,000		50,000		30,000	80	
100		30,000		50,000	no F14		#N/A		#N/A		no F14			30,000		50,000		30,000	100	
150		30,000		50,000	no F14		#N/A		#N/A		no F14			30,000		50,000		30,000	150	
200	#N/A		#N/A	#N/A	#N/A		F14C	#N/A	F14B/C	#N/A	#N/A		#N/A	#N/A	#N/A	30,000	200			
225	F14	50,000	50,000	no F14		50,000		50,000		no F14		50,000	30,000	50,000	30,000	225				
260		50,000	50,000	no F14		50,000		50,000		no F14		50,000	35,000	50,000	#N/A	260				
300		#N/A	#N/A	#N/A		#N/A		#N/A		#N/A		#N/A	#N/A	#N/A	#N/A	300				
400		50,000	50,000	no F14		50,000	50,000	no F14		50,000	#N/A	50,000	50,000	F14	50,000	400				
600	ZTS2	65,000	ZTS2	65,000	ZTS2	65,000	ZTS2	65,000	ZTS2	65,000	ZTS2	65,000	F14	50,000	ZTS2	65,000	F14	50,000	600	
800		65,000		65,000		65,000	ZTS2	85,000	ZTS2	85,000	ZTS2	85,000		ZTS2		65,000		65,000	800	
1,000	ZTS	85,000	ZTS	85,000	ZTS	85,000	ZBTS	85,000	ZBTS	85,000	ZBTS	85,000	ZTS	85,000	ZTS	85,000	ZTS	85,000	1,000	
1,200		85,000		85,000		85,000	ZBTS	85,000	ZBTS	85,000	ZBTS	85,000		ZBTS		85,000		85,000	1,200	
1,600	ZTS	100,000	ZTS	100,000	ZTS	100,000	ZBTS	100,000	ZBTS	100,000	ZBTS	100,000	ZTS	100,000	ZTS	100,000	ZTS	#N/A	1,600	
2,000		100,000		100,000		100,000	ZBTS	100,000	ZBTS	100,000	ZBTS	100,000		ZBTS		100,000		100,000	100,000	2,000
2,600		100,000		100,000		100,000	ZBTS	100,000	ZBTS	100,000	ZBTS	100,000		ZBTS		100,000		100,000	100,000	2,600
3,000		100,000		100,000		100,000	ZBTS	100,000	ZBTS	100,000	ZBTS	100,000		ZBTS		100,000		100,000	100,000	3,000
4,000	100,000	100,000	100,000	100,000	100,000	100,000	100,000	100,000	100,000	100,000	100,000	100,000	#N/A	#N/A	100,000	100,000	4,000			

UL references:

- ZTS -- E23911, Vol. 4, Sec. 10 (1,000-1,200A), Sec. 12 (1,600-2,000A), Sec. 11 (2,600-3,000A), Sec. 15 (4,000A).
- ZTS2 -- E23911, Vol. 4, Sec. 9 ( 600- 800A).
- ZBTS -- E67544, Vol. 1, Sec. 5 ( 800-1,200A), Sec. 8 (1,600-3,000A), Sec. 9 (4,000A)

NOTE: THIS IS A PARTIAL EXCERPT FROM TECHNICAL BULLETIN TB1102. FOR MORE INFORMATION ON SPECIFIC COORDINATED BREAKER USE, PLEASE REQUEST THE COMPLETE DOCUMENT TB-1102



**GeneratorJoe**

4016 Quartz Drive  
 Santa Rosa, CA 95405  
 Phone: 707 539-9003  
 Fax: 707 539-5212  
 Email: sales@generatorjoe.NET  
 Web www.generatorjoe.NET